

CERTIFICATE OF COMPLIANCE

Certificate Number 20190208-E251761
Report Reference E251761-20100724
Issue Date 2019-FEBRUARY-08

Issued to: Rockwell Automation/ Allen-Bradley
1201 S 2nd St
Milwaukee WI 53204-2410

**This certificate confirms that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations.
CAN/CSA C22.2 No. 213-M1987, Non-incendive Electrical
Equipment for Use in Class I, Division 2 Hazardous
Locations


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number 20190208-E251761
Report Reference E251761-20100724
Issue Date 2019-FEBRUARY-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Programmable Logic Controllers, Models T9110 Processor, 1715-AENTR Processor, T9111 Processor, T9401 Digital Input, T9402 Digital Input, 1715-IB16D Digital Input, T9431 Analog Input, T9432 Analog Input, 1715-IF16 Analog Input, T9451 Digital Output, 1715-OB8DE Digital Output, T9481 Analog Output and T9482 Analog Output, 1715-OF8I Analog Output for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.

Listed accessories for use with PLCs, T9100 Processor Backplane, T9101 Dual Backplane, 1715-A2A Dual Backplane, T9300 I/O Backplane, 1715-A3I0 I/O Backplane, T9801 Digital Input Termination Assembly, 1715-TASIB16D Digital Input Termination Assembly, T9802 Digital Input Termination Assembly, 1715-TADIB16D Digital Input Termination Assembly, T9803 Digital Input Termination Assembly, T9831 Analog Input Termination Assembly, 1715-TASIF16 Analog Input Termination Assembly, T9832 Analog Input Termination Assembly, 1715-TADIF16 Analog Input Termination Assembly, T9833 Analog Input Termination Assembly, T9851 Digital Output Termination Assembly, 1715-TASOB8DE Digital Output Termination Assembly, T9852 Digital Output Termination Assembly, 1715-TADOB8DE Digital Output Termination Assembly, T9892 Digital Termination Assembly, T9881 Analog Output Termination Assembly, 1715-TASOF8 Analog Output Termination Assembly and T9882 Analog Output Termination Assembly, 1715-TADOF8 Analog Output Termination Assembly.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

